



1500 Series

Photoluminescent Egress Signage

PRODUCT DESCRIPTION

Photoluminescent egress signage used in conjunction with photoluminescent handrail demarcation, floor demarcations, and obstruction markers to provide an intuitive egress pathway navigation system for building occupants and first responders

IDEAL FOR

- Stairs required by code to have luminous path markings

PERFORMANCE

- Luminance (ASTM E2072) - Pass
- Illuminates instantly upon power failure and maintains illumination for a minimum of 90 minutes when charged with 1 footcandle (11 lux) for 60 mins.
- Meets Requirements of NYC RS-1A for:
 - Toxicity (SMP 800C)
 - Radioactivity (ASTM D3648)
 - Flame spread (ASTM D635)
 - Washability (ASTM D4828)

MATERIALS

- Aluminum sheet: 3105, ASTM B221
- Phosphorescent pigment:
 - Strontium Aluminate Oxide

ADVANTAGES

- Non-toxic, non-radioactive, and VOC free

LIMITATIONS

- Egress pathways must be lit with a minimum of 1 footcandle (11 lux) as required per IBC 1025.5

FINISH

- ANSI Safety green print
- High gloss photoluminescent coating

RELATED PRODUCTS

- Photoluminescent floor demarcation
- Photoluminescent stair nosings
- Photoluminescent handrail demarcation

ADDITIONAL DOCUMENTATION

- Product details
- Installation instructions
- Maintenance and cleaning
- Warranty
- SDS documentation
- LEED documentation

WARRANTY

Standard Warranty: 1 year
Optional Warranty: 5 years with Certified Installer
Sample warranty available upon request.

1500 Series Photoluminescent Egress Signage

Item #	DIRECTIONAL SIGNAGE	Size
1505	Running man right, Right arrow	5.25" x 9"
1506	Running man Left, Left Arrow	5.25" x 9"
1507	Running man right, Down Arrow	5.25" x 9"
1508	Running man Left, Down Arrow	5.25" x 9"
1509	Running man right, Up Arrow	5.25" x 9"
1510	Running man Left, Up Arrow	5.25" x 9"
1511	Running man right, Diagonal Up Arrow	5.25" x 9"
1512	Running man Left, Diagonal Up Arrow	5.25" x 9"
1513	Running man right, Diagonal Down Arrow	5.25" x 9"
1514	Running man Left, Diagonal Down Arrow	5.25" x 9"
Item #	DIRECTIONAL SIGNAGE ARROWS AND EXIT	Size
1515	Exit, Running man right, Right arrow	9.5" x 8.5"
1516	Exit, Running man Left, Left Arrow	9.5" x 8.5"
1517	Exit, Running man right, Down Arrow	9.5" x 8.5"
1518	Exit, Running man Left, Down Arrow	9.5" x 8.5"
1519	Exit, Running man right, Up Arrow	9.5" x 8.5"
1520	Exit, Running man Left, Up Arrow	9.5" x 8.5"
1521	Exit, Running man right, Diagonal Up Arrow	9.5" x 8.5"
1522	Exit, Running man Left, Diagonal Up Arrow	9.5" x 8.5"
1523	Exit, Running man right, Diagonal Down Arrow	9.5" x 8.5"
1524	Exit, Running man Left, Diagonal Down Arrow	9.5" x 8.5"
1545	Exit, Running man right, Right arrow	5.25" x 16"
1546	Exit, Running man Left, Left Arrow	5.25" x 16"
1547	Exit, Running man right, Down Arrow	5.25" x 16"
1548	Exit, Running man Left, Down Arrow	5.25" x 16"
1549	Exit, Running man right, Up Arrow	5.25" x 16"
1550	Exit, Running man Left, Up Arrow	5.25" x 16"
1551	Exit, Running man right, Diagonal Up Arrow	5.25" x 16"
1552	Exit, Running man Left, Diagonal Up Arrow	5.25" x 16"
1553	Exit, Running man right, Diagonal Down Arrow	5.25" x 16"
1554	Exit, Running man Left, Diagonal Down Arrow	5.25" x 16"
Item #	STAIRWAY DOOR MOUNTED SIGNAGE	Size
1500	Exit, Running man right, Diagonal Down Arrow	8" x 18"
1501	Final Exit	10" x 14"
1502	Exit through Lobby (for Directional Pathway)	18" x 8"
1503	Exit (Final Exit Door Marker)	5.25" x 12.5"
1504	Not an Exit	8.5" x 6"
1529	Door Handle Marking, Running man Left	5" x 11"
1530	Door Handle Marking, Running man Right	5" x 11"
1531	Panic Bar Marking	2" x 22"
1532	Door Handle Placard	4" x 4"